

-----Original Message-----

**From:** Catanzaro, Jeff - TP4JMC [mailto:JCatanzaro@socalgas.com]

**Sent:** Monday, May 14, 2001 12:49 PM

**To:** Steve Rusch

**Subject:** Stocker Inglewood proposed EG

Dear Steve,

The following is SoCalGas' best **estimate** of our ability to serve your proposed electrical generation(EG) project at Inglewood. Please note that actual service may differ should another power plant or other future large gas user commit to service in this general area prior to Stocker's commitment to proceed.

Per your request, we evaluated our transmission and distribution systems to provide service for the proposed 110 MW EG at your production facility adjacent to your gas processing plant (5640 S. Fairfax Avenue, Inglewood), using your request for approximately 24 MMcfd of natural gas.

I am pleased to tell you that we can presently offer firm transportation service for this 24 MMcfd demand. We will serve your EG meter set assembly (MSA) from the same 12 inch line into which your production field sporadically feeds.

A *rough* estimate of the cost for this connection including the MSA and including CIAC taxes (35%) is \$100K. We expect (but cannot guarantee) that Stocker will experience pressures ranging from 200 psig min to 465 psig (line MAOP) at the MSA.

Please contact me if you have any questions or wish to discuss next steps. We look forward to serving your power generation project.

Sincerely,

Jeff Catanzaro  
213-244-2683